CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No.: TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID	:	**CP-2018-02-28-06** **Date: 03/03/2018**
Customer	:	Assistant Executive Engineer, Shettyhalli Sub division, BBMP, Bangalore.
Address	:	Shettyhalli Sub division, BBMP, Bangalore.
Project Name	:	Improvements to CC roads 10th, 11th, 12th cross roads at Ravindra Nagara in Ward no.13 in Shettyhalli Sub division.
Agency	:	Sri. K. Jagadish, No.3424, 6th cross, Gayathrinagara, Bengaluru- 560021
Customer's Reference	:	EE/DD/WO/232/17-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	28-02-2018
Sample ID No	:	2018-02-28-06 /07
Customer ID	:	Concrete Concrete Pavement
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M30 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 03/03/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	150.66 X 151.48 X 150.44	22822	8.154	527.2	23.1	
2	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	150.69 X 150.47 X 150.99	22674	8.198	526.0	23.2	22.9
3	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	150.49 X 150.66 X 150.95	22673	8.198	510.1	22.5	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

AE

CIVIL PRO BANGALORE Sig..... Date.....

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL | GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Date: 03/03/2018

Lab ID	:	CP-2018-02-28-06
Customer	:	Assistant Executive Engineer, Shettyhalli Sub division, BBMP, Bangalore.
Address	:	Shettyhalli Sub division, BBMP, Bangalore.
Project Name	:	Improvements to CC roads 10th, 11th, 12th cross roads at Ravindra Nagara in Ward no.13 in Shettyhalli Sub division.
Agency	:	Sri. K. Jagadish, No.3424, 6th cross, Gayathrinagara, Bengaluru- 560021
Customer's Reference	:	EE/DD/WO/232/17-18
Source of Sample	:	Sample supplied by Agency
Sample Condition	:	Satisfactory
Date of Receipt	:	28-02-2018
Sample ID No	:	2018-02-28-06 /09
Customer ID	:	Concrete Concrete Pavement
Sample Type /Size	:	150X150X150 mm
Sample grade/Age	:	M30 / 7 Days Compressive Strength
Reference to BIS codes	:	IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5
Date of test	:	03/03/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	149.32 X 151.44 X 150.32	22613	8.199	556.3	24.6	24.6
2	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	149.87 X 150.48 X 150.62	22552	8.145	557.0	24.7	
3	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	150.43 X 150.22 X 150.97	22598	8.139	553.6	24.5	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

CIVIL PRO Sig..... Date..... BANGALORE

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner

CIVIL PRO
AN ISO 9001 : 2008 COMPANY &NABL ACCREDITED LABORATORY AS PER ISO/IEC 17025:2005
4, 7TH MAIN MALLESWARAM, BANGALORE -3
Certificate No : TC-5548

Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2018-02-28-06**

Date: 03/03/2018

Customer : Assistant Executive Engineer, Shettyhalli Sub division, BBMP, Bangalore.

Address : Shettyhalli Sub division, BBMP, Bangalore.

Project Name : Improvements to CC roads 10th, 11th, 12th cross roads at Ravindra Nagara in Ward no.13 in Shettyhalli Sub division.

Agency : Sri. K. Jagadish, No.3424, 6th cross, Gayathrinagara, Bengaluru- 560021

Customer's Reference : EE/DD/WO/232/17-18

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 28-02-2018

Sample ID No : 2018-02-28-06 /11

Customer ID : Concrete Concrete Pavement

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 03/03/2018

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	149.37 X 151.34 X 151.42	22606	8.137	522.2	23.1	23.5
2	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	150.87 X 151.77 X 150.73	22898	8.164	547.3	23.9	
3	Concrete Concrete Pavement	M30	24/02/2018	03/03/2018	150.38 X 150.49 X 150.37	22631	8.126	529.6	23.4	

Note:

The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

AE

CIVIL PRO BANGALORE Sig..... Date.....

FOR CIVIL Pro.

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

****End of Report****

M : 9972924526 | Tel : +91 80 23444801 | e : rechan6630@yahoo.co.in, civilproexperts@gmail.com

HIGHWAY & BUILDING MATERIALS TESTING LABORATORY | STRUCTURAL |
GEO TECHNICAL | PROJECT MANAGEMENT | SURVEYING SERVICES |

Scanned by CamScanner